

Declaration of Performance

according to Annex III of the Regulation (EU) No. 305/2011

HENSOMASTIK® Mixed Penetration Seal EI 90 / EI 120

DoP No. EN 2016-08-003 HENSOMASTIK® Mixed Penetration Seal EI 90 / EI 120

- | | |
|--|---|
| 1. Product Type
Unique identification code of the product-type | HENSOMASTIK® Mixed Penetration Seal EI 90 / EI 120 |
| 2. Type
Batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) | see the label on the bucket |
| 3. Intended use
or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer | The mixed penetration seal is used to seal off openings in fire resistant walls and floors penetrated by installations and serves to preserve the fire resistance of the wall or floor in vicinity of the penetrations. Depending on the installation situation the mixed penetration seal reaches a maximum fire resistance class of EI 90 and EI 120. |
| 4. Name, registered trade name
or registered trade mark and contact address of the manufacturer as required under Article 11(5) | Rudolf Hensel GmbH, Lack- und Farbenfabrik,
Lauenburger Landstraße 11
21039 Börnsen Germany |
| 5. Contact Address
where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2) | Not relevant (see 4) |
| 6. AVCP
System or systems of assessment and verification of constancy of performance (AVCP) of the construction product as set out in CPR, Annex V | System 1 |
| 7. Notified body (hEN)
In case of the declaration of performance (DoP) concerning a production product covered by a harmonized standard | Not relevant |
| 8. Notified Body (ETA)
In case of the declaration of performance concerning a construction product for which a European Technical Assessment (ETA) has been issued | European technical approval ETA 15/0295 issued by UL International (UK) based on ETAG 026-2. The notified body 0761-CPR performed third party tasks as set out in Annex V under system 1 and issued certificate of conformity 0761-CPR-0510. |

RUDOLF HENSEL GMBH

Lack- und Farbenfabrik

Lauenburger Landstraße 11 Tel. +49 (0) 40/72 10 62-10
21039 Börnsen | Germany Fax +49 (0) 40/72 10 62-52

E-Mail: info@rudolf-hensel.de
Internet: www.rudolf-hensel.de



9. Declared Performance

Essential characteristics	Performance	Technical specification
Reaction to fire	See Annex A ETA 15/0295	EN 13501-1
Fire Resistance	Plastic Pipes: EI 90 and EI 120 Metal Pipes: EI 90 and EI 120 Cables: EI 90 See Annex A ETA 15/0295	EN 1366-3 and EN 13501-2
Emission of dangerous substances	Substances registered as dangerous substances in the list of the European Commission are not contained	
Durability and serviceability	Type X	ETAG 026-2 and EOTA TR 024

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance (DoP) is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for the manufacturer and on behalf of the manufacturer:

Volker Thewes
Managing Director

ppa. Anja Peter (Dipl.-Ing. FH)
Technical Director

Börnsen, 17th of August 2016

Note: Besides the declaration of performance our approvals, technical data sheets and material safety data sheets for our HENSOTHERM® and HENSOMASTIK® products are available as pdf download on www.rudolf-hensel.de
For further questions concerning our products, our technical team is available by phone +49 40 72 10 62-48.